



Annual Drinking Water Quality Report
Consumer Confidence Report
January 1 to December 31, 2021

NEVADA SPECIAL UTILITY DISTRICT
PWS ID NUMBER: TX 0430053
(972) 843-2608



This report is intended to provide you with important information about your drinking water and the efforts made by Nevada SUD to provide safe drinking water. The analysis was made by using the data from the most recent U. S. Environmental Protection Agency (EPA) required tests and is presented in the attached pages. We hope this information helps you become more knowledgeable about what is in your drinking water. For more information regarding this report please contact Johnny Rudisill/General Manager at (972) 843-2608 or email at nevadawater@nevadawater.org. Este reporte incluye información importante sobre el agua para tomar. Para asistencia en español, favor de llamar al telefono (972) 843-2608.

Nevada SUD had a water loss of 3.2% for 2021

Public Participation Opportunities

Nevada SUD regular monthly board meeting is the second Monday of every month at 7:00 pm. The location of the meeting is 108 N Warren Street, Nevada, TX 75173

Source Water Susceptibility Assessment (SWSA)

The TCEQ has completed a Source Water Assessment for all drinking water systems that own their sources. The report describes the susceptibility and types of constituents that may come into contact with your drinking water source based on human activities and natural conditions. The system from which we purchase our water received the assessment report. For more information on source water assessments and protection at our system, contact Johnny Rudisill at (972) 843-2608.

A Source Water Susceptibility Assessment for your drinking water source(s) is currently being updated by the Texas Commission on Environmental Quality. This information describes the susceptibility and types of constituents that may come into contact with your drinking water source based on human activities and natural conditions. The information contained in the assessment allows us to focus source water protection strategies.

The source of drinking water used by Nevada SUD is purchased surface water. We purchase the surface water from North Texas Municipal Water District (TX0430044 North), Wylie Treatment Plant. It comes from the following Lake/River/Reservoir/Aquifer: LAVON LAKE.

For more information about your sources of water, please refer to the Source Water Assessment Viewer available at the following URL: <http://gis3.tceq.state.tx.us/swav/Controller/Index.jsp?wtrsrc=>

Further details about sources and source-water assessments are available in Drinking Water Watch at the following URL: <http://dww2.tceq.texas.gov/DWW/>

Sources of Drinking Water

The sources of drinking water (both tap and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPA's Safe Drinking Water Hotline at (800) 426-4791.

Contaminants that may be present in source water include:

- *Microbial contaminants*, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- *Inorganic contaminants*, such as salts and metals, which can be naturally-occurring or result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- *Pesticides and herbicides*, which may come from a variety of sources such as agriculture, urban storm water runoff, and residential uses.
- *Organic chemical contaminants*, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban storm water runoff, and septic systems.
- *Radioactive contaminants*, which can be naturally-occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

Contaminants may be found in drinking water that may cause taste, color, or odor problems. These types of problems are not necessarily causes of health concerns. For more information on taste, odor, or color of drinking water, please contact Nevada SUD's business office at (972) 843-2608.

You may be more vulnerable than the general population to certain microbial contaminants, such as *Cryptosporidium*, in drinking water. Infants, some elderly, or immunocompromised persons such as those undergoing chemotherapy for cancer; persons who have undergone organ transplants; those who are undergoing treatment with steroids; and people with HIV/AIDS or other immune system disorders, can be particularly at risk from infections. You should seek advice about drinking water from your physician or health care providers. Additional guideline on appropriate means to lessen the risk of infection by *Cryptosporidium* are available from the Safe Drinking Water Hotline (800) 426-4791.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Nevada SUD is responsible for providing high quality drinking water, but we cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

Water Quality Test Results - Definitions

The following tables contain scientific terms and measures, some of which may require explanation.

Action Level (AL): The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Action Level Goal (ALG): The level of a contaminant in drinking water below which there is no known or expected risk to health. ALGs allow for a margin of safety.

Avg: Regulatory compliance with some MCLs are based on running annual average or monthly samples.

Level 1 Assessment: A Level 1 Assessment is a study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.

Level 2 Assessment: A level 2 Assessment is a very detailed study of the water system to identify potential problems and determine (if possible) why an E. coli MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.

Maximum Contaminant Level (MCL): The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal (MCLG): The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum Residual Disinfectant Level (MRDL): The highest level of disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG): The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contamination.

MFL: million fibers per liter (a measure of asbestos)

mrem: millirems per year (a measure of radiation absorbed by the body)

Water Quality Test Results - Definitions Continued

na: not applicable
 NTU: nephelometric turbidity units (a measure of turbidity)
 pCi/L: picocuries per liter (a measure of radioactivity)
 ppb: micrograms per liter or parts per billion - or one ounce in 7,350,000 gallons of water
 ppm: milligrams per liter or parts per million - or one ounce in 7,350 gallons of water
 ppt: parts per trillion, or nanograms per liter (ng.L)
 ppq: parts per quadrillion or pictograms per liter (pg/L)
Treatment Technique or TT: A required process intended to reduce the level of a contaminant in drinking water

Lead and Copper Rule

The Lead and Copper Rule protects public health by minimizing lead and copper levels in drinking water, primarily by reducing water corrosivity. Lead and copper enter drinking water mainly from corrosion of lead and copper containing plumbing materials.

Violations Table

Violation Type	Violation Begin Date	Violation End Date	Violation Explanation
Nevada SUD had no violations	N/A	N/A	No violations.

Lead and Copper

Lead and Copper	Date Sampled	MCLG	Action Level (AL)	90th Percentile	# of Sites Over AL	Units	Violation	Likely Source of Contamination
Copper	6/19/2019	1.3	1.3	0.6272	0	ppm	No	Erosion of natural deposits; leaching from wood preservatives; corrosion of household plumbing systems.
Lead	6/19/2019	0	15	1.24	0	ppb	No	Corrosion of household plumbing systems; erosion of natural deposits.

Coliform Bacteria

Maximum Contaminant Level Goal	Total Coliform Maximum Contaminant Level	Number of E. coli Positive Results	Number of Assessments Required	Number of Assessments Performed	Violation	Likely Source of Contamination
0	1 positive monthly sample	0	0	0	No	Naturally present in the environment.

Note: Reported monthly tests found no fecal coliform bacteria. Coliforms are bacteria that are naturally present in the environment and are used as an indicator that other, potentially harmful, waterborne pathogens may be present or problems that a potential pathway exists through which contamination may enter the drinking water distribution system. If coliforms are found, this indicates the need to look for potential problems in water treatment or distribution. When this occurs, systems are required to conduct assessments(s) to identify problems and to correct any problems that were found during these assessments. A Level 1 assessment must be conducted when a PWS exceeds one or more of the Level 1 treatment technique triggers specified previously. Under the rule, this self-assessment consists of a basic examination of the source water, treatment, distribution system and relevant operational practices. The PWS should look at conditions that could have occurred prior to and caused the total coliform-positive sample. Example conditions include treatment process interruptions, loss of pressure, maintenance and operation activities, recent operational changes, etc. In addition, the PWS should check the conditions of the following elements: sample sites, distribution system, storage tanks, source water, etc. If the number of positive samples is below the required action level, then no assessment is performed. *E. coli* are bacteria whose presence indicates that the water may be contaminated with human or animal wastes. Human pathogens in these waste can cause short-term effects, such as diarrhea, cramps, nausea, headaches, or other symptoms. They may pose a great health risk for infants, young children, the elderly, and people with severely compromised immune systems. When *E. coli* bacteria are found, this indicates the need to look for potential problems in water treatment or distribution. When this occurs, systems are required to conduct Level 2 assessment(s) to identify problems and to correct any problems that were found during these assessments.

Regulated Contaminants								
Disinfectants and By-Products	Collection Date	Highest Level Detected	Range of Individual Samples	MCLG	MCL	Units	Violation	Likely Source of Contamination
Total Haloacetic Acids (HAA5)	2021	33.6	12.8 - 33.6	No goal for the total	60	ppb	No	By-product of drinking water disinfection.
Total Trihalomethanes (TTHm)	2021	39.7	19.4 - 39.7	No goal for the total	60	ppb	No	By-product of drinking water disinfection.
Bromate	2021	69.2	5.27 - 69.2	5	10	ppb	No	By-product of drinking water ozonation.

Note: Not all sample results may have been used for calculating the Highest Level Detected because some results may be part of an evaluation to determine where compliance sampling should occur in the future. TCEQ only requires one sample annually for compliance testing.

Inorganic Contaminants	Collection Date	Highest Level Detected	Range of Levels Detected	MCLG	MCL	Units	Violation	Likely Source of Contamination
Antimony	2021	Levels lower than detect level	0 - 0	6	6	ppb	No	Discharge from petroleum refineries; fire retardants, ceramics, electronics; solder; and test addition.
Arsenic	2021	Levels lower than detect level	0 - 0	0	10	ppb	No	Erosion of natural deposits; runoff from orchards, runoff from glass and electronics production wastes.
Barium	2021	0.038	0.037 - 0.038	2	2	ppm	No	Discharge from drilling wastes; discharge from metal refineries; erosion of natural desposits.
Beryllium	2021	Levels lower than detect level	0 - 0	4	4	ppb	No	Discharge from metal refineries and coal-burning factories; discharge from electrical, aerospace, and defense industries.
Cadmium	2021	Levels lower than detect level	0 - 0	5	5	ppb	No	Corrosion of galvanized pipes; erosion of natural deposits; discharge from metal refineries; runoff from waste batteries and paints.
Chromium	2021	Levels lower than detect level	0 - 0	100	100	ppb	No	Discharge from steel and pulp mills; erosion of natural deposits.
Cyanide	2021	Levels lower than detect level	86.9 - 86.9	200	200	ppb	No	Discharge from steel/metal factory; discharge from plastics and fertilizer factories.
Fluoride	2021	0.48	0.306 - 0.480	4	4	ppm	No	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories.
Mercury	2021	Levels lower than detect level	0 - 0	2	2	ppb	No	Erosion of natural deposits; discharge from refineries and factories; runoff from landfills; runoff from cropland.
Nitrate (measured as Nitrogen)	2021	0.802	0.110 - 0.802	10	10	ppm	No	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits.
Selenium	2021	Levels lower than detect level	0 - 0	50	50	ppb	No	Discharge from petroleum and metal refineries; erosion of natural deposits; discharge from mines.
Thallium	2021	Levels lower than detect level	0 - 0	0.5	2	ppb	No	Discharge from electronics, glass, and leaching from ore-processing sites; drug factories.

Nitrate Advisory: Nitrate in drinking water at levels above 10 ppm is a health risk for infants of less than six months of age. High nitrate levels in drinking water can cause blue baby syndrome. Nitrate levels may rise quickly for short periods of time because of rainfall or agricultural activity. If you are caring for an infant you should ask advice from your health care provider.

Radioactive Contaminants	Collection Date	Highest Level Detected	Range of Levels Detected	MCLG	MCL	Units	violation	Likely Source of Contamination
Beta/photon emitters	2021	Levels lower than detect level	0 - 0	0	50	pCi/L	No	Decay of natural and man-made deposits.
Gross alpha excluding radon and uranium	2021	Levels lower than detect level	0 - 0	0	15	pCi/L	No	Erosion of natural deposits.
Radium	2021	Levels lower than detect level	0 - 0	0	5	pCi/l	No	Erosion of natural deposits.

Synthetic organic contaminants including pesticides and hericides	Collection Date	Highest Level Detected	Range of Levels Detected	MCLG	MCL	Units	Violation	Likely Source of Contamination
2, 4, 5 - TP (Silvex)	2019	Levels lower than detect level	0 - 0	50	50	ppb	No	Residue of banned herbicide.
2, 4 - D	2019	Levels lower than detect level	0 - 0	70	70	ppb	No	Runoff from herbicide used on row crops.
Alachlor	2021	Levels lower than detect level	0 - 0	0	2	ppb	No	Runoff from herbicide used on row crops.
Aldicarb	2019	Levels lower than detect level	0 - 0	1	3	ppb	No	Runoff from herbicide used on row crops.
Aldicarb Sulfone	2019	Levels lower than detect level	0 - 0	1	2	ppb	No	Runoff from herbicide used on row crops.
Aldicarb Sulfoxide	2019	Levels lower than detect level	0 - 0	1	4	ppb	No	Runoff from herbicide used on row crops.
Altrazine	2021	0.3	0.2 - 0.3	3	3	ppb	No	Runoff from herbicide used on row crops.
Benzo (a) pyrene	2021	Levels lower than detect level	0 - 0	0	200	ppt	No	Leaching from linings of water storage tanks and distribution lines.
Carbofuran	2019	Levels lower than detect level	0 - 0	40	40	ppb	No	Leaching from soil fumigant used on rice and alfalfa.
Chlordane	2021	Levels lower than detect level	0 - 0	0	2	ppb	No	Residue of banned herbicide.
Dalapon	2019	Levels lower than detect level	0 - 0	200	200	ppb	No	Runoff from herbicide used on rights of way.
Di (2-ethylhexyl) adipate	2021	Levels lower than detect level	0 - 0	400	400	ppb	No	Discharge from chemical factories.
Di (2-ethylhexyl) phthalate	2021	Levels lower than detect level	0 - 0	0	6	ppb	No	Discharge from rubber and chemical factories.
Dibromochloropropane (DBCP)	2019	Levels lower than detect level	0 - 0	0	200	ppt	No	Runoff / leaching from soil fumigant used on soybeans, cotton, pineapples, and orchards.
Dinoseb	2019	Levels lower than detect level	0 - 0	7	7	ppb	No	Runoff from herbicide used on soybeans and vegetables.
Endrin	2021	Levels lower than detect level	0 - 0	2	2	ppb	No	Residue of banned herbicide.

Synthetic organic contaminants including pesticides and herbicides	Collection Date	Highest Level Detected	Range of Levels Detected	MCLG	MCL	Units	Violation	Likely Source of Contamination
Ethylene dibromide	2019	Levels lower than detect level	0 - 0	0	50	ppt	No	Discharge from petroleum refineries.
Heptachlor	2021	Levels lower than detect level	0 - 0	0	400	ppt	No	Residue of banned herbicide.
Heptachlor epoxide	2021	Levels lower than detect level	0 - 0	0	200	ppt	No	Breakdown of heptachlor.
Hexachlorobenzene	2021	Levels lower than detect level	0 - 0	0	1	ppb	No	Discharge from metal refineries and agricultural chemical factories.
Hexachlorocyclopentadiene	2021	Levels lower than detect level	0 - 0	50	50	ppb	No	Discharge from chemical factories.
Lindane	2021	Levels lower than detect level	0 - 0	200	200	ppt	No	Runoff / leaching from insecticide used on cattle, lumber, and gardens.
Methoxychlor	2021	Levels lower than detect level	0 - 0	40	40	ppb	No	Runoff / leaching from insecticide used on fruits, vegetables, alfalfa, and livestock.
Oxamyl (Vydate)	2019	Levels lower than detect level	0 - 0	200	200	ppb	No	Runoff / leaching from insecticide used on apples, potatoes, and tomatoes.
Pentachlorophenol	2019	Levels lower than detect level	0 - 0	0	1	ppb	No	Discharge from wood preserving factories.
Picloram	2019	Levels lower than detect level	0 - 0	500	500	ppb	No	Herbicide runoff.
Simazine	2021	0.12	0.08 - 0.12	4	4	ppb	No	Herbicide runoff.
Toxaphene	2021	Levels lower than detect level	0 - 0	0	3	ppb	No	Runoff / leaching from insecticide used on cotton and cattle.

Volatile Organic Contaminants	Collection Date	Highest Level Detected	Range of Levels Detected	MCLG	MCL	Units	violation	Likely Source of Contamination
1, 1, 1 - Trichloroethane	2021	Levels lower than detect level	0 - 0	200	200	ppb	No	Discharge from metal degreasing sites and other factories.
1, 1, 2 - Trichloroethane	2021	Levels lower than detect level	0 - 0	3	5	ppb	No	Discharge from industrial chemical factories.
1, 1 - Dichloroethylene	2021	Levels lower than detect level	0 - 0	7	7	ppb	No	Discharge from industrial chemical factories.
1, 2, 4 - Trichlorobenzene	2021	Levels lower than detect level	0 - 0	70	70	ppb	No	Discharge from textile-finishing factories.
1, 2 - Dichloroethane	2021	Levels lower than detect level	0 - 0	0	5	ppb	No	Discharge from industrial chemical factories.
1, 2 - Dichloropropane	2021	Levels lower than detect level	0 - 0	0	5	ppb	No	Discharge from industrial chemical factories.
Benzene	2021	Levels lower than detect level	0 - 0	0	5	ppb	No	Discharge from factories; leaching from gas storage tanks and landfills.

Volatile Organic Contaminants	Collection Date	Highest Level Detected	Range of Levels Detected	MCLG	MCL	Units	violation	Likely Source of Contamination
Carbon Tetrachloride	2021	Levels lower than detect level	0 - 0	0	5	ppb	No	Discharge from chemical plants and other industrial activities.
Chlorobenzene	2021	Levels lower than detect level	0 - 0	100	100	ppb	No	Discharge from chemical and agricultural chemical factories.
Dichloromethane	2021	Levels lower than detect level	0 - 0	0	5	ppb	No	Discharge from pharmaceutical and chemical factories.
Ethylbenzene	2021	Levels lower than detect level	0 - 0	0	700	ppb	No	Discharge from petroleum refineries.
Styrene	2021	Levels lower than detect level	0 - 0	100	100	ppb	No	Discharge from rubber and plastic factories; leaching from landfills.
Tetrachloroethylene	2021	Levels lower than detect level	0 - 0	0	5	ppb	No	Discharge from factories and dry cleaners.
Toluene	2021	Levels lower than detect level	0 - 0	1	1	ppm	No	Discharge from petroleum factories.
Trichloroethylene	2021	Levels lower than detect level	0 - 0	0	5	ppb	No	Discharge from metal degreasing site and other factories.
Vinyl Chloride	2021	Levels lower than detect level	0 - 0	0	2	ppb	No	Leaching from PVC piping; discharge from plastics factories.
Xylenes	2021	Levels lower than detect level	0 - 0	10	10	ppm	No	Discharge from petroleum factories; discharge from chemical factories.
cis - 1, 2 - Dichloroethylene	2021	Levels lower than detect level	0 - 0	70	70	ppb	No	Discharge from industrial chemical factories.
o - Dichlorobenzene	2021	Levels lower than detect level	0 - 0	600	600	ppb	No	Discharge from industrial chemical factories.
p - Dichlorobenzene	2021	Levels lower than detect level	0 - 0	75	75	ppb	No	Discharge from industrial chemical factories.
trans - 1, 2 - Dichloroethylene	2021	Levels lower than detect level	0 - 0	100	100	ppb	No	Discharge from industrial chemical factories.

Turbidity				
	Limit (Treatment Technique)	Level Detected	Violation	Likely Source of Contamination
Highest single measurement	1 NTU	0.39 NTU	No	Soil runoff.
Lowest monthly percentage (%) meeting limit	0.3 NTU	98.80%	No	Soil runoff.

NOTE: Turbidity is a measurement of the cloudiness of the water caused by suspended particles. We monitor it because it is a good indicator of water quality and the effectiveness of our filtration.

Cryptosporidium and Giardia					
Contaminants	Collection Date	Highest Level Detected	Range of Levels Detected	Units	Likely Source of Contaminants
Cryptosporidium	2021	0	0 - 0	(Oo) Cysts/L	Human and animal fecal waste.
Giardia	2021	0	0 - 0	(Oo) Cysts/L	Human and animal fecal waste.

Maximum Residual Disinfectant Level								
Disinfectant Type	Year	Average Level of Quarterly Data	Lowest Result of Single Sample	Highest Result of Single Sample	MRDL	MRDLG	Units	Source of Chemical
Chlorine Residual (Chloramines)	2021	2.50	0.82	3.75	4.0	<4.0	ppm	Disinfectant used to control microbes.
Chlorine Dioxide	2021	0	0	0	0.8	0.8	ppm	Disinfectant.
Chlorite	2021	0.105	0	0.97	1.0	NA	ppm	Disinfectant.

NOTE: Water providers are required to maintain a minimum chlorine disinfection level of 0.5 parts per million (ppm) for systems disinfecting with chloramines and an annual average chlorine disinfection residual level between 0.5 (ppm) and 4 parts per million (ppm). Water systems using free chlorine are required to maintain a minimum chlorine disinfection residual level of 0.2 parts per million (ppm). The 0.21 ppm result was sampled during our temporary change in disinfectant from chloramines to free chlorine.

Total Organic Carbon					
	Collection Date	Highest Level Detected	Range of Levels Detected	Units	Likely Source of Contamination
Source Water	2021	4.66	3.69 - 4.66	ppm	Naturally present in the environment.
Drinking Water	2021	4.01	2.01 - 4.01	ppm	Naturally present in the environment.
Removal Ratio	2021	46.00	1.9 - 46.0	% removal *	N/A

NOTE: Total organic carbon (TOC) has no health effects. The disinfectant can combine with TOC to form disinfection by-products. Disinfection is necessary to ensure that water does not have unacceptable levels of pathogens. By-products of disinfection include trihalomethanes (THMs) and haloacetic acids (HAA) which are reported elsewhere in this report. *Removal ration is the percent of TOC removed by the treatment process divided by the percent of TOC required by TCEQ to be removed.

Unregulated Contaminants					
Contaminants	Collection Date	Highest Level Detected	Range of Levels Detected	Units	Likely Source of Contamination
Chloroform	2021	14.70	8.87 - 14.70	ppb	By-product of drinking water disinfection.
Bromoform	2021	2.89	<1.00 - 2.89	ppb	By-product of drinking water disinfection.
Bromodichloromethane	2021	14.5	7.27 - 14.50	ppb	By-product of drinking water disinfection.
Dibromochloromethane	2021	9.65	4.99 - 9.65	ppb	By-product of drinking water disinfection.

NOTE: Bromoform, chloroform, dichlorobromomethane, and dibromochloromethane are disinfection by-products. There is no maximum contaminant level for these chemicals at the entry point to distribution.

Disinfectant Residual Table									
Disinfectant	Year	Average Level	Minimum Level	Maximum Level	MRDL	MRDLG	Unit	Violation	Likely Source of Contamination
Total Chlorine (NH ₂ CL)	2021	2.50	0.82	3.75	4.0	4.0	ppm	No	Water additive used to control microbes.

Secondary and Other Constituents Not Regulated					
Contaminants	Collection Date	Highest Level Detected	Range of Levels Detected	Units	Likely Source of Contaminants
Aluminum	2021	Levels lower than detect level	0 - 0	ppm	Erosion of natural deposits.
Calcium	2021	77.5	34.5 - 77.5	ppm	Abundant naturally occurring element.
Chloride	2021	78.9	4.78 - 78.9	ppm	Abundant naturally occurring element; used in water purification; by-product of oil field activity.
Iron	2021	Levels lower than detect level	0 - 0	ppm	Erosion of natural deposits; iron or steel water delivery equipment or facilities.
Magnesium	2021	4.43	3.40 - 4.43	ppm	Abundant naturally occurring element.
Manganese	2021	0.038	0 - 0.038	ppm	Abundant naturally occurring element.
Nickel	2021	0.006	0.004 - 0.006	ppm	Erosion of natural deposits.
pH	2021	9.12	7.56 - 9.12	ppm	Measure of corrosivity of water.
Silver	2021	Levels lower than detect level	0 - 0	ppm	Erosion of natural deposits.
Sodium	2021	81.1	33.0 - 81.1	ppm	Erosion of natural deposits; by-products of oil field activity.
Sulfate	2021	153	22.4 - 153	ppm	Naturally occurring; common industrial by-products; by-products of oil field activity.

Secondary and Other Constituents Not Regulated

Contaminants	Collection Date	Highest Level Detected	Range of Levels Detected	Units	Likely Source of Contaminants
Total Alkalinity as CaCO ₃	2021	128	65 - 128	ppm	Naturally occurring soluble mineral salts.
Total Dissolved Solids	2021	444	186 - 444	ppm	Total dissolved mineral constituents in water.
Total Hardness as CaCO ₃	2021	192	96 - 192	ppm	Naturally occurring calcium.
Zinc	2021	Levels lower than detect level	0 - 0	ppm	Moderately abundant naturally occurring element used in the metal industry.